

FY 2020 Performance Data

Influent/Effluent	Units	Value	Solids Handling	Units	Value
Average Daily Flow	MGD	30.9	Solids to Belt Filter press (BFP)	%	4.44
Average Raw cBOD	mg/L	158	BFP Cake Solids Contents	%	23.1
Average Final cBOD	mg/L	2.0	BFP Cake to Incinerators	Wet Tons	77,066
Average Raw TSS	mg/L	183	BFP Cake to Incinerators	Wet Tons/hr	8.83
Average Final TSS	mg/L	2.5			
Average Raw TN	mg/L	27.0			
Average Final TN	mg/L	4.7			
Average Final TN (May-Oct)	mg/L	4.8			
Average Raw TP	mg/L	3.54			
Average Final TP	mg/L	0.14			
Average Final TP (Apr-Oct)	mg/L	0.16			
Plant Performance					
cBOD Removal	%	98.5	Full Time Staff		61
TSS Removal	%	98.4	Electrical Energy Used	Million kW h	16.2
TN Removal	%	85.3	Natural Gas Used	Million CF	90.1
TP Removal	%	95.4			