

## FY 2021 Performance Data

Influent/Effluent	Units	Value	Solids Handling	Units	Value
Average Daily Flow	MGD	28.8	Solids to Belt Filter press (BFP)	%	4.33
Average Raw cBOD	mg/L	181	BFP Cake Solids Contents	%	23.0
Average Final cBOD	mg/L	2.5	BFP Cake to Incinerators	Wet Tons	80,079
Average Raw TSS	mg/L	186	BFP Cake to Incinerators	Wet Tons/hr	9.23
Average Final TSS	mg/L	2.5			
Average Raw TN	mg/L	26.6			
Average Final TN	mg/L	4.0			
Average Final TN (May-Oct)	mg/L	4.0			
Average Raw TP	mg/L	3.57			
Average Final TP	mg/L	0.18			
Average Final TP (Apr-Oct)	mg/L	0.19			
<b>Plant Performance</b>					
cBOD Removal	%	98.4	Full Time Staff		
TSS Removal	%	98.5	Electrical Energy Used	Million kW h	17.5
TN Removal	%	84.0	Natural Gas Used	Million CF	87.5
TP Removal	%	94.7			