



Local Limits (adopted July 2015)

The following pollutant limits are established to protect against pass-through and interference. No industry shall discharge wastewater containing in excess of the following:

Maximum Limits

Aluminum	168 mg/L
Arsenic	3.7 mg/L
Beryllium	1.2 mg/L
Cadmium	0.16 lbs./day <sup>1, 2</sup>
Chromium	1.3 mg/L
Copper	1.09 mg/L
Lead	1.0 mg/L
Mercury	0.03 mg/L
Nickel	8.6 mg/L
Silver	.50 mg/L
Zinc	3.7 mg/L
Cyanide	2.0 mg/L
Total Nitrogen	325 mg/L
Total Phosphorus	715 lbs./day <sup>1, 2</sup>
Fats, Oils, and Grease	225 mg/L
pH	6.5 to 11.5 s.u.

<sup>1</sup> lbs/day = pollutant concentration (mg/L) X Flow (MGD) X 8.34 (conversion factor).

<sup>2</sup> Total available loading for all Industrial Users. The sum of all allocations must not exceed the total available loading for Industrial users. Allocations are given to each Industry on an individual basis.